



Haverhill

Engineering Department, Room 300
Tel: 978-374-2335 Fax: 978-373-8475
John H. Pettis III, P.E. - City Engineer
JPettis@CityOfHaverhill.com

October 7, 2021

MEMO TO: HAVERHILL CONSERVATION COMMISSION

Subject: *Linwood Street, M 411 B 138 L 5, NOI for Construction of a
Single Family Home*

I have reviewed the plan for the subject project. My only comment is that the driveway apron should be built up slightly to keep the roadway stormwater runoff in roadway, as it currently is by the existing bit. conc. berm. I am ok with this note being added at the Development Review stage, if acceptable to the Commission.

Please contact me if you have any questions.

Sincerely,

John H. Pettis III, P.E.
City Engineer

C: Stankovich, Ward
Merrimack Engineering