



Sewer Manhole Test Report

City _____
 Engineer © _____

Date: _____
 Weather: _____

Right-Of-Way:	Project/Subdivision Name:
Drainlayer:	Reference Plan:
Testing Company:	Inspector:

Testing procedure shall be as specified in ASTM C1244-02 (or latest revision) – Standard Test Method For Concrete Sewer Manholes by Negative Air Pressure (Vacuum) Test, further as modified by the allowable vacuum loss shall not exceed 1" Hg (mercury) within one (1) minute for all manhole sizes.

Station	Manhole Diameter & Depth	Starting Vacuum (Inch Hg)	Ending Vacuum (Inch Hg)	Vacuum Loss (Inch Hg)	Pass Or Fail

Comments: _____



City
Engineer ©

Sewer Manhole Test Report

Page 2

Station	Manhole Diameter & Depth	Starting Vacuum (Inch Hg)	Ending Vacuum (Inch Hg)	Vacuum Loss (Inch Hg)	Pass Or Fail

Comments: _____
